

Certificate of Compliance



YADAV MEASUREMENTS PVT. LTD.

Plot no.373-375, RIICO Bhamashah Industrial Area Kaladwas, Udaipur-313003 India

Email: yadav.measurements@ymllabs.com Website: www.yadavmeasurements.com

Certificate Number

: COC / 2018-2019 / 05 Dated: 19/06/2018

Tests

Accuracy Test

: Active energy class 1.0 and reactive energy class 2.0 as per

EN/ IEC 62052-11: 2003 Amend 1, EN/ IEC 62053-21:2003 Amend 1 and

EN /IEC 62053-23: 2003 + Amend 1 clause 8.1 (table 6 & 7)

Voltage Variation Test

: EN/ IEC 62053-21:2003 Amend 1 clause 8.2

Frequency Variation Test: EN/ IEC 62053-21:2003 Amend 1 & clause 8.2

Report reference

: UKAS accredited certificate no.

YMPL/2018-2019/214/1/17 & YMPL/2018-2019/214/3/18

Issue date

: 16-June-2018

Issued to

: SOCOMEC S.A.S 1 RUE DE WESTHOUSE,

67235, BENFELD CEDEX, FRANCE

This is to certify that representative samples of :

Single phase, two wire, ac static energy meter, type: **COUNTIS E13** & **COUNTIS E14**, current rating 5 - 80A, 230 VAC to 240 VAC, 50Hz, Accuracy class: 1.0

have been tested by Yadav Measurements Private Limited in accordance with the standard(s) indicated on this certificate for tests mentioned above. This is to certify that the specimen is/are in conformity with the requirements of the standards as mentioned above.

Additional Information:

Nil

UMESH SONI (Manager)